



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

13 November 2017

San Jose Water Company

Attn: Sarah Richardson

110 W. Taylor Street

San Jose, CA 95110

RE: Lead Sampling in Schools

Work Order: 17K0210

Enclosed are the results of analyses for samples received by the laboratory on 11/01/17 22:10. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Sheri Speaks

Sheri L. Speaks For David S. Pingatore

Project Manager



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

San Jose Water Company 110 W. Taylor Street San Jose CA, 95110	Project: Lead Sampling in Schools Project #: Lead in Schools Project Mgr: Sarah Richardson	Reported: 11/13/17 08:09
--	--	-----------------------------

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
4310011-BBF-A	17K0210-01	Water	11/01/17 06:18	11/01/17 22:10
4310011-BBF-B	17K0210-02	Water	11/01/17 06:11	11/01/17 22:10
4310011-BBF-C	17K0210-03	Water	11/01/17 06:03	11/01/17 22:10
4310011-BBF-D	17K0210-04	Water	11/01/17 05:53	11/01/17 22:10
4310011-BBF-E	17K0210-05	Water	11/01/17 05:45	11/01/17 22:10



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBF-A
Laboratory ID: 17K0210-01

Report Date: 11/13/17 08:09
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY
Source Name: 4310011-BBF-A PIEDMONT MIDDLE- SAMPLE LOC. 1
Sampled by: Client
Employed by: San Jose Water Co.

Sample Date: 11/01/17 06:18
Sample Received: 11/01/17 22:10
User ID: HEN
System Number: 4310011

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBF-B
Laboratory ID: 17K0210-02

Report Date: 11/13/17 08:09
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY
Source Name: 4310011-BBF-B PIEDMONT MIDDLE- SAMPLE LOC. 2
Sampled by: Client
Employed by: San Jose Water Co.

Sample Date: 11/01/17 06:11
Sample Received: 11/01/17 22:10
User ID: HEN
System Number: 4310011

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBF-C
Laboratory ID: 17K0210-03

Report Date: 11/13/17 08:09
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY
Source Name: 4310011-BBF-C PIEDMONT MIDDLE- SAMPLE LOC. 3
Sampled by: Client
Employed by: San Jose Water Co.

Sample Date: 11/01/17 06:03
Sample Received: 11/01/17 22:10
User ID: HEN
System Number: 4310011

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	14		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBF-D
Laboratory ID: 17K0210-04

Report Date: 11/13/17 08:09
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY
Source Name: 4310011-BBF-D PIEDMONT MIDDLE- SAMPLE LOC. 4
Sampled by: Client
Employed by: San Jose Water Co.

Sample Date: 11/01/17 05:53
Sample Received: 11/01/17 22:10
User ID: HEN
System Number: 4310011

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBF-E
Laboratory ID: 17K0210-05

Report Date: 11/13/17 08:09
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY
Source Name: 4310011-BBF-E PIEDMONT MIDDLE- SAMPLE LOC. 5
Sampled by: Client
Employed by: San Jose Water Co.

Sample Date: 11/01/17 05:45
Sample Received: 11/01/17 22:10
User ID: HEN
System Number: 4310011

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

* Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.



Alpha Analytical Laboratories Inc.
 e-mail: clientservices@alpha-labs.com

LEAD SAMPLING IN SCHOOLS CHEMICAL CHAIN OF CUSTODY RECORD

Lab No. 17K0210 Page of

Cooler / Lab Temperature

2.6

School Name:

Piedmont Middle

LAB CONTACT:

David Pingatore
 cell - 925.872.9637

attn: Adam Feffer
 Adam.Feffer@sjwater.com
 408.279.7828 phone
 408.292.5812 fax

CLIENT:
 San Jose Water Co.
 1221A South Bascom Ave
 San Jose, CA 95128

LOCATION ID	FIELD SAMPLE COMMENTS	SERVICE POINT ID	SAMPLE NAME / STATE SAMPLE ID	DATE		Temp (Celsius)	PH	Field Tests		Requested Chemical Analyses
				TIME	TIME			Chlorine - Free (mg/L)	Chlorine - Total (mg/L)	
1	Lead in Schools School Name - School District Piedmont Middle - Berryessa Union School District	907310070	4310011-BBF-A	11-1-17 6:18		16.8	7.1	0.04	2.45	X
2	Lead in Schools School Name - School District Piedmont Middle - Berryessa Union School District	907310070	4310011-BBF-B	11-1-17 6:11		15.7	7.0	0.04	2.35	X
3	Lead in Schools School Name - School District Piedmont Middle - Berryessa Union School District	907310070	4310011-BBF-C	11-1-17 6:03		12.6	7.0	0.00	0.5	X
4	Lead in Schools School Name - School District Piedmont Middle - Berryessa Union School District	907310070	4310011-BBF-D	11-1-17 5:53		16.3	7.0	0.00	2.32	X
5	Lead in Schools School Name - School District Piedmont Middle - Berryessa Union School District	907310070	4310011-BBF-E	11-1-17 5:45		16.6	7.5	0.03	1.00	X

Comments/ Notes
 Please notify us of the Field Sample ID (FSID) once generated in Locus.

Sampling Program: Lead Sampling in Schools	
Sampled by:	Date: <u>11/1/17</u> Time: <u>1530</u>
Relinquished by:	Date: <u>11-1-17</u> Time: <u>19:45</u>
Relinquished by:	Date: <u>11-1-17</u> Time: <u>22:10</u>
Relinquished by:	Date: <u>11-1-17</u> Time: <u>22:10</u>

T.A.T.
 10 business days