



*Alpha*

Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

14 November 2017

San Jose Water Company

Attn: Sarah Richardson

110 W. Taylor Street

San Jose, CA 95110

RE: Lead Sampling in Schools

Work Order: 17K0317

Enclosed are the results of analyses for samples received by the laboratory on 11/02/17 22:00. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

*Sheri Speaks*

Sheri L. Speaks For David S. Pingatore

Project Manager



Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

San Jose Water Company 110 W. Taylor Street San Jose CA, 95110	Project: Lead Sampling in Schools Project #: Lead in Schools Project Mgr: Sarah Richardson	Reported: 11/14/17 06:46
--	--	-----------------------------

### Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
4310011-BBE-A	17K0317-01	Water	11/02/17 05:48	11/02/17 22:00
4310011-BBE-B	17K0317-02	Water	11/02/17 06:22	11/02/17 22:00
4310011-BBE-C	17K0317-03	Water	11/02/17 06:12	11/02/17 22:00
4310011-BBE-D	17K0317-04	Water	11/02/17 06:03	11/02/17 22:00
4310011-BBE-E	17K0317-05	Water	11/02/17 05:56	11/02/17 22:00



Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBE-A  
Laboratory ID: 17K0317-01

Report Date: 11/14/17 06:46  
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY  
Source Name: 4310011-BBE-A NORTHWOOD ELEM.- SAMPLE LOC. 1  
Sampled by: Client  
Employed by: San Jose Water Co.

Sample Date: 11/02/17 05:48  
Sample Received: 11/02/17 22:00  
User ID: HEN  
System Number: 4310011

Data submitted to DDW via EDT

### Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBE-B  
Laboratory ID: 17K0317-02

Report Date: 11/14/17 06:46  
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY  
Source Name: 4310011-BBE-B NORTHWOOD ELEM.- SAMPLE LOC. 2  
Sampled by: Client  
Employed by: San Jose Water Co.

Sample Date: 11/02/17 06:22  
Sample Received: 11/02/17 22:00  
User ID: HEN  
System Number: 4310011

Data submitted to DDW via EDT

### Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBE-C  
Laboratory ID: 17K0317-03

Report Date: 11/14/17 06:46  
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY  
Source Name: 4310011-BBE-C NORTHWOOD ELEM.- SAMPLE LOC. 3  
Sampled by: Client  
Employed by: San Jose Water Co.

Sample Date: 11/02/17 06:12  
Sample Received: 11/02/17 22:00  
User ID: HEN  
System Number: 4310011

Data submitted to DDW via EDT

### Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBE-D  
Laboratory ID: 17K0317-04

Report Date: 11/14/17 06:46  
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY  
Source Name: 4310011-BBE-D NORTHWOOD ELEM.- SAMPLE LOC. 4  
Sampled by: Client  
Employed by: San Jose Water Co.

Sample Date: 11/02/17 06:03  
Sample Received: 11/02/17 22:00  
User ID: HEN  
System Number: 4310011

Data submitted to DDW via EDT

### Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 4310011-BBE-E  
Laboratory ID: 17K0317-05

Report Date: 11/14/17 06:46  
Laboratory Code: 1610

System Name: SAN JOSE WATER COMPANY  
Source Name: 4310011-BBE-E NORTHWOOD ELEM.- SAMPLE LOC. 5  
Sampled by: Client  
Employed by: San Jose Water Co.

Sample Date: 11/02/17 05:56  
Sample Received: 11/02/17 22:00  
User ID: HEN  
System Number: 4310011

Data submitted to DDW via EDT

### Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



*Alpha*

---

Alpha Analytical Laboratories Inc.

e-mail: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

#### **Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit

\* Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.





**LEAD SAMPLING IN SCHOOLS CHEMICAL CHAIN OF CUSTODY RECORD**

Lab No. 17K0317

Page \_\_\_ of

Cooler / Lab Temperature  
2.2°

School Name:

Northwood Elementary

CLIENT:

San Jose Water Co.  
1221A South Bascom Ave  
San Jose, CA 95128

LAB CONTACT:

attn: Adam Feffer  
Adam.Feffer@sjwater.com  
408.279.7828 phone  
408.292.5812 fax

David Pingatore  
cell - 925.872.9637

LOCATION ID	FIELD SAMPLE COMMENTS School Name - School District	SERVICE POINT ID	SAMPLE NAME / STATE SAMPLE ID Water System Number-School ID-Sample ID	DATE	Requested Chemical Analyses  Lead (Pb)	Field Tests			
				TIME		Temp (Celsius)	pH	Chlorine - Free (mg/L)	Chlorine - Total (mg/L)
1	Lead in Schools Northwood - Berryessa Union School District	3478000086	4310011-BBE-A	11-2-17 5:48	x	20.2	8.09	0.04	1.97
2	Lead in Schools Northwood - Berryessa Union School District	3478000086	4310011-BBE-B	11-2-17 6:22	x	18.7	8.05	0.01	0.06
3	Lead in Schools Northwood - Berryessa Union School District	3478000086	4310011-BBE-C	11-2-17 6:12	x	16.1	7.93	0.05	1.40
4	Lead in Schools Northwood - Berryessa Union School District	3478000086	4310011-BBE-D	11-2-17 6:03	x	20.4	7.76	0.00	0.01
5	Lead in Schools Northwood - Berryessa Union School District	3478000086	4310011-BBE-E	11-2-17 5:56	x	20.7	8.23	0.09	2.19

Comments/ Notes

Please notify us of the Field Sample ID (FSID) once generated in Locus.

Sampled by:	Sampling Program: <b>Lead Sampling in Schools</b>		
Relinquished by:	Received by:	Date: 11/2/17	Time: 15:30
Relinquished by:	Received by:	Date: 11-2-17	Time: 19:34
Relinquished by:	Received by:	Date: 11-2-17	Time: 22:00
<b>T.A.T.</b> 10 business days			